

Certificate of Conformity

Product certificate number

No. 2622/0029-D-CER/E1

Issued to:

Holder:

Cellcron Technologies Pvt. Ltd.
Daniyalpur Chowk, Airport Road, Karnal, Haryana, India (132001)



Trademark:



Manufacturer:

Cellcron Technologies Pvt. Ltd.
Daniyalpur Chowk, Airport Road, Karnal, Haryana, India (132001)

It is certified that the product:

Type of generating unit: Hybrid Inverter

Models

Technical Data

Nominal power

Nominal voltage

Nominal frequency

Firmware version

Number of phases

Isolation Transformer

Galaxy 6G

EU 3kw

24v

3000

230

50

Galaxy 6G

EU 3kw

48v

3000

230

50

Galaxy 6G

EU 3.6kw

48v

3600

230

50

Galaxy 6G

EU 5kw

48v

5000

230

50

Galaxy 6G

EU 6kw

48v

6000

230

50

Software version: Ver5980

Communication version: Verc339

Hardware version: Ver1.0

Single Phase

No

Is in compliance with the standards:

IEC 60068-2-1: 2007

Environmental testing. Part 2-1. Test Ae: Cold

IEC 60068-2-2: 2007

Environmental testing. Part 2-2. Test Be: Dry heat

IEC 60068-2-14: 2009

Environmental testing. Part 2-14. Test Nb: Changes of temperature

IEC 60068-2-30: 2005

Environmental testing. Part 2-30. Test Db – Variant 1: Damp heat, cyclic (12 h + 12 h)

This certificate is based upon the test results of the Test Report nº GZES211002949104-01. This report confirms that one sample of the above-mentioned products has been tested with positive result against the requirements of these IEC standards for environmental conditions.

The above-mentioned generating unit is certified according to the SGS internal process 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate supersedes the certificate 2622/0029-D-CER

First issued on 09th March 2022

This certificate is valid until 09th March 2027

Madrid, 04th April 2022

Daniel Arranz Muñoz
Certification Manager

