



Certificate of Conformity

By the product certificate number:

No. 2622/0029-E-CER/E1

Issued to:

License holder:

Cellcronic Technologies Pvt. Ltd.

Daniyalpur Chowk, Airport Road, Karnal, Haryana, India (132001)

Trademark:

CELLCRONIC

Manufacturer:

Cellcronic Technologies Pvt. Ltd.

Daniyalpur Chowk, Airport Road, Karnal, Haryana, India (132001)

It is certified that the product:

Type of generating unit

Hybrid Inverter

Models:		Galaxy 6G EU 3kw 24v	Galaxy 6G EU 3kw 48v	Galaxy 6G EU 3.6kw 48v	Galaxy 6G EU 5kw 48v	Galaxy 6G EU 6kw 48v
Technical Data:	Nominal power [kW]	3000	3000	3600	5000	6000
	Nominal voltage [V]	230	230	230	230	230
	Nominal frequency [Hz]	50	50	50	50	50
	Firmware version		Software version: Ver5980 Communication version: Verc339 Hardware version: Ver1.0			
	Number of phases		Single Phase			
	Isolation Transformer		No			

Is in compliance with the standard:

IEC 62109-1: 2010, 62109-2: 2011

Safety of power converters to use in Photovoltaic Power System

This certificate is based upon the test results of the Test Report nº GZES211002949102-02

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate supersedes the certificate 2622/0029-B-CER First issued on 09th March 2022 This certificate is valid until 09th March 2027

Madrid, 04th April 2022

Daniel Arranz Muñiz Certification Manager





SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions
for Product Certification at www.sgs.com/terms, and conditions.
The status and validity of the certificate can be checked scanning the
QR code above included or through the following web link database:
https://www.sgs.com/en/certified-clients-and-products/electrical-products
This document cannot be reproduced partially

No. 2622/0029-B-CER/E1